

Setting for grid operator of Chile

SolaX Power Network Technology (Zhe jiang) Co. , Ltd.
hereby confirms that the following inverters fulfill RE_12438:

| | | | |
|--------------------------|--------------------------|--------------------------|--------------------------|
| X1-Hybrid-3.0-N-C | X1-Hybrid-3.7-N-C | X1-Hybrid-4.6-N-C | X1-Hybrid-5.0-N-C |
| X1-Hybrid-3.0-D-C | X1-Hybrid-3.7-D-C | X1-Hybrid-4.6-D-C | X1-Hybrid-5.0-D-C |
| X1-Hybrid-3.0-N-E | X1-Hybrid-3.7-N-E | X1-Hybrid-4.6-N-E | X1-Hybrid-5.0-N-E |
| X1-Hybrid-3.0-D-E | X1-Hybrid-3.7-D-E | X1-Hybrid-4.6-D-E | X1-Hybrid-5.0-D-E |
| X1-Fit-3.7C | X1-Fit-3.7E | | |
| X1-Fit-4.6C | X1-Fit-4.6E | | |
| X1-Fit-5.0C | X1-Fit-5.0E | | |

SolaX Power Network Technology (Zhe jiang) Co. , Ltd.

No.288 Shizhu Road,Tonglu Economic Development Zone,Dongxing District,Tonglu City,
Zhejiang Province, China.



Technical manager
2019.11.15

1、 over/under frequency and over/under voltage

| Protection. Frequency tests | | | | | | |
|-----------------------------|-----------|------|-----------|-------|-----------|--------|
| Function | Limit | | Setting | | Trip test | |
| | Frequency | Time | Frequency | Time | Frequency | Time |
| U/F stage 1 | 47.5Hz | 0.1s | 47.5Hz | 0.08s | 47.5Hz | 0.078s |
| O/F stage 1 | 51.5Hz | 0.1s | 51.5Hz | 0.08s | 51.5Hz | 0.074s |


| Protection. Voltage tests | | |
|---------------------------|---------------|--------|
| | Under Voltage | |
| Parameter | Voltage | Time |
| Protection limit | 176.0V | 0.1s |
| Actual Setting | 176.0V | 0.08s |
| Trip value(test result) | | |
| L1 | 175.7V | 0.089s |

| Protection. Voltage tests | | | | |
|---------------------------|--------------|------------|---------|--------|
| | Over Voltage | | | |
| Parameter | Voltage | Time | Voltage | Time |
| Protection limit | 242.0V | 600s(0.1s) | 253.0V | 0.1s |
| Actual Setting | 242.0V | 600s(0.1s) | 253.0V | 0.08s |
| Trip value(test result) | | | | |
| L1 | 242.5V | 594s | 253.5V | 0.093s |

2、Reconnection

| Reconnection generate electrical power | | P | |
|--------------------------------------------|---------------------------------------------------------|----------------------------------------------------------|-------------|
| Setting value | Min.voltage for connected to grid.....: | 187.0V | |
| | Max.voltage for connected to grid.....: | 242.0 V | |
| | Min.Frequency for connected to grid.....: | 47.5Hz | |
| | Max.Frequency for connected to grid.....: | 51.2Hz | |
| | Observation time(180s).....: | 60s | |
| Test: | | | |
| | | Voltage conditions | |
| In voltage range after voltage failure | 85%U _N for twice of setting observation time | 110%U _N for twice of setting observation time | |
| Reconnection time[s] | 188.6V | 77s | 240.7V 76s |
| Limit: | Reconnection after setting observation time(60s) | | |
| | | Frequency conditions | |
| In frequency range after frequency failure | 47.5Hz for twice of setting observation time | 51.2Hz for twice of setting observation time | |
| Reconnection time[s] | 47.55Hz | 77s | 51.15Hz 78s |
| Limit: | Reconnection after setting observation time(60s) | | |

Recover power gradient 734s



3、 Active anti-islanding protection

| Active anti-islanding protection | | | | | | | | | P |
|----------------------------------|-------------------------------|----------------------------------|------------------------------|------------------------------|---------------|----------------------|-----------------------|-----------------|--------------|
| Disconnection limit: | | | | 2s | | | | | |
| No. | P _{EUT} (% of rated) | Reactive power (Q _L) | P _{AC} (% of rated) | Q _{AC} (% of rated) | Run time (ms) | P _{EUT} (W) | Actual Q _f | V _{dc} | Remarks |
| 1 | 100 | 100 | 0 | 0 | 373 | 4947 | 0,96 | 560,5 | Test A at BL |
| 2 | 100 | 100 | -10 | -10 | 482 | 4943 | 0,92 | 562,7 | Test A at BL |
| 3 | 100 | 100 | -10 | -5 | 441 | 4943 | 0,9 | 565,3 | Test A at BL |
| 4 | 100 | 100 | -10 | 0 | 572 | 4939 | 0,9 | 564,4 | Test A at BL |
| 5 | 100 | 100 | -10 | +5 | 168 | 4957 | 0,88 | 563,6 | Test A at BL |
| 6 | 100 | 100 | -10 | +10 | 130 | 4940 | 0,86 | 563,4 | Test A at BL |
| 7 | 100 | 100 | -5 | -10 | 518 | 4917 | 0,97 | 564,4 | Test A at BL |
| 8 | 100 | 100 | -5 | -5 | 408 | 4942 | 0,96 | 563,7 | Test A at IB |
| 9 | 100 | 100 | -5 | 0 | 342 | 4943 | 0,94 | 562,5 | Test A at IB |
| 10 | 100 | 100 | -5 | +5 | 202 | 4934 | 0,92 | 564,4 | Test A at IB |
| 11 | 100 | 100 | -5 | +10 | 151 | 4932 | 0,90 | 564,7 | Test A at BL |
| 12 | 100 | 100 | 0 | -10 | 151 | 4943 | 0,94 | 564,0 | Test A at BL |
| 13 | 100 | 100 | 0 | -5 | 550 | 4937 | 1,02 | 564,0 | Test A at IB |
| 14 | 100 | 100 | 0 | +5 | 166 | 4933 | 0,97 | 563,1 | Test A at IB |
| 15 | 100 | 100 | 0 | +10 | 139 | 4937 | 0,95 | 562,1 | Test A at BL |
| 16 | 100 | 100 | +5 | -10 | 137 | 4937 | 0,97 | 562,2 | Test A at IB |
| 17 | 100 | 100 | +5 | -5 | 392 | 4939 | 1,07 | 563,5 | Test A at BL |
| 18 | 100 | 100 | +5 | 0 | 700 | 4946 | 1,04 | 562,8 | Test A at IB |
| 19 | 100 | 100 | +5 | +5 | 176 | 4946 | 1,02 | 563,0 | Test A at BL |
| 20 | 100 | 100 | +5 | +10 | 184 | 4933 | 0,99 | 560,2 | Test A at IB |
| 21 | 100 | 100 | +10 | -10 | 142 | 4937 | 1,04 | 563,5 | Test A at BL |
| 22 | 100 | 100 | +10 | -5 | 363 | 4938 | 1,11 | 562,8 | Test A at IB |
| 23 | 100 | 100 | +10 | 0 | 283 | 4937 | 1,09 | 563,9 | Test A at BL |
| 24 | 100 | 100 | +10 | +5 | 182 | 4947 | 1,06 | 563,2 | Test A at IB |
| 25 | 100 | 100 | +10 | +10 | 162 | 4940 | 1,03 | 562,3 | Test A at BL |
| 12 | 66 | 66 | 0 | -5 | 382 | 3307 | 1,04 | 342,3 | Test B at IB |
| 13 | 66 | 66 | 0 | -4 | 374 | 3306 | 1,03 | 347,1 | Test B at IB |
| 14 | 66 | 66 | 0 | -3 | 399 | 3305 | 1,02 | 349,2 | Test B at IB |
| 15 | 66 | 66 | 0 | -2 | 331 | 3305 | 1,01 | 348,4 | Test B at IB |
| 16 | 66 | 66 | 0 | -1 | 480 | 3305 | 1 | 347,6 | Test B at IB |
| 17 | 66 | 66 | 0 | 0 | 428 | 3305 | 1 | 272,7 | Test B at BL |
| 18 | 66 | 66 | 0 | 1 | 325 | 3306 | 1 | 345,7 | Test B at IB |
| 19 | 66 | 66 | 0 | 2 | 380 | 3306 | 0,99 | 346,6 | Test B at IB |
| 20 | 66 | 66 | 0 | 3 | 253 | 3304 | 0,98 | 348,2 | Test B at IB |

| | | | | | | | | | |
|----|----|----|---|----|-------|------|------|-------|--------------|
| 21 | 66 | 66 | 0 | 4 | 216 | 3305 | 0,98 | 347,8 | Test B at IB |
| 22 | 66 | 66 | 0 | 5 | 196 | 3305 | 0,97 | 340,1 | Test B at IB |
| 23 | 33 | 33 | 0 | -5 | 122 | 1650 | 1,04 | 137,2 | Test C at IB |
| 24 | 33 | 33 | 0 | -4 | 362 | 1649 | 1,03 | 135,9 | Test C at IB |
| 25 | 33 | 33 | 0 | -3 | 302 | 1648 | 1,02 | 136,8 | Test C at IB |
| 26 | 33 | 33 | 0 | -2 | 371 | 1649 | 1,01 | 135,6 | Test C at IB |
| 27 | 33 | 33 | 0 | -1 | 496 | 1649 | 0,99 | 136,4 | Test C at IB |
| 28 | 33 | 33 | 0 | 0 | 250 | 1650 | 0,98 | 136,8 | Test C at BL |
| 29 | 33 | 33 | 0 | 1 | 305 | 1649 | 0,98 | 135,5 | Test C at IB |
| 30 | 33 | 33 | 0 | 2 | 172 | 1649 | 0,97 | 135,0 | Test C at IB |
| 31 | 33 | 33 | 0 | 3 | 126.2 | 1650 | 0,95 | 137,8 | Test C at IB |
| 33 | 33 | 33 | 0 | 4 | 165 | 1649 | 0,94 | 137,6 | Test C at IB |
| 34 | 33 | 33 | 0 | 5 | 173 | 1650 | 0,93 | 136,4 | Test C at IB |

Note:

P_{EUT} : EUT output power.

P_{AC} : Active power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.

Q_{AC} : Reactive power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.

BL: balance condition, IB: imbalance condition.